

Our PRE-PAID Standard LUBEKIT1 for testing, **Gear, Hydraulic, Turbine, Transmission Engine etc.** The sample kit contains, 60ml PETG bottle, sample tubing, bottle & equipment ID labels and Postal Jiffy Bag and PRE-PAID return addressed Postage Label (Please note the Jiffy Bag and return address label are not included in our international kits (OMKLUBE)). Price is inclusive of the analysis and report. All reports are issued in pdf format by e-mail. Turnaround time from receipt of the sample in our laboratory is 2 working days. Analysis covers Wear, Contamination & Chemistry along with our analysts' comments and where appropriate any actions or recommendations.

#### For wear the LUBEKIT1 tests for;

- A large range of different metals Aluminium, Chromium, Copper, Iron, Lead, Nickel, Silver, Tin, Vanadium and Titanium.
- Also the **Ferrous Wear Index** gives an indication of the total measure of Iron (regardless of size) in the sample. This technique is used to determine early component wear.

#### The contamination tests include;

- **Particle Count (ISO)** – Particle counting is actually a test for particle contaminant levels and not specifically for wear debris. It does not distinguish between wear and dirt particles, but if it can be determined that nonferrous contamination has remained stable, then an increase in the particle count must be attributable to wear.

A magnet can be used to modify the particle count to count ferrous debris only. There are various ways of doing this, but essentially a magnet holds back the ferrous debris while the nonferrous debris is flushed from the sample, after which a ferrous debris particle count is performed.

Particle counts are invariably reported according to ISO 4406:99. Other standards do exist, but they are not as commonly used. ISO 4406:99 returns a three-digit solid contamination code.

The method of particle counting is not as important as performing the test properly. It is important to note that only results from the same method should be compared.

- **ISO 4406 Standard:**

The ISO 4406/2000 classification of particle contents was introduced to facilitate comparisons in particle counting. Sudden breakdown in an oil system is often caused by large particles (>14 micron) in the oil while slower, progressive faults, e.g. wear and tear, are caused by the smaller particles (4-6 micron). This is one of the explanations why the particle reference sizes were set to 4 micron, 6 micron and 14 micron in ISO 4406/2000.

A typical sample contains in every 100 ml of oil:

- 450,000 particles >4 micron
- 120,000 particles >6 micron
- 14,000 particles >14 micron

Introduced in the ISO classification table (below), this oil sample has a contamination class of 19/17/14

FROM	TILL	ISO NUMBER
8.000.000	16.000.000	24
4.000.000	8.000.000	23
2.000.000	4.000.000	22
1.000.000	2.000.000	21
500.000	1.000.000	20
250.000	500.000	19
130.000	250.000	18
64.000	130.000	17
32.000	64.000	16
16.000	32.000	15
8.000	16.000	14
4.000	8.000	13
2.000	4.000	12
1.000	2.000	11
500	1.000	10
250	500	9
130	250	8
64	130	7
32	64	6
16	32	5
8	16	4
4	8	3
2	4	2
1	2	1

- **Water K. Fischer** – The Karl Fischer test measures the exact amount of free and dissolved water molecules contained in the oil sample. The Karl Fisher test is reported in a numerical value.
- **Boron** - Used as a corrosion inhibitor, anti-wear and anti-oxidant additive. Concentration levels vary greatly depending on oil brand. Also Boron is used in extreme pressure compounds and dispersants. It can also appear as a contaminant as it can be used in the manufacture of coolant conditioners. Boron can come from a few areas; it can come in with water, coolant, from worn seals or airborne dust.
- **Silicon** - Although silicon is usually seen as an indication of dirt entry it can have many different sources. Silicon is part of a chemical added to oils to stop them foaming so silicon can be an additive. It is usually found in a concentration of 5 to 10 ppm, so do not be surprised to see silicon in new engine oil samples. Do not panic, this is not due to dirt. Silicon is found in chemicals used in coolant conditioners so it can show up as a contaminant if there is an internal coolant leak, along with sodium.
- **Sodium** - The most common chemicals contain sodium so this is the first indication of an internal coolant leak. Other

chemicals found in coolant conditioners contain elements such as molybdenum, phosphorus, chromium, boron and silicon. Elements that make up the physical structure of the cooling system and can leach into the oil (from either the water or the oil side of the cooler) include copper, tin, lead and silver. Sodium can also be found as an additive in some engine oils (often replacing calcium or magnesium) but this is a lot rarer than it used to be. Some greases contain sodium as part of the soap and sodium will be evident if the oil is contaminated with sea water.

### The Chemistry tests include;

- Testing for Calcium, Magnesium, Molybdenum, Phosphorus, Zinc and Manganese to check the level of additives within the oil to make sure that they are in spec.
- **Oil Viscosity** - Monitoring oil's viscosity is a critical factor in extending a machines life and overall reliability, accurate monitoring and managing of oil's viscosity can also prevent costly breakdowns. The viscosity of an oil is the most important physical effect of an oil and plays a role in energy efficiency.

Tests can be carried out in the following ways:

- **40 degrees Celsius** - Viscosity, or oil weight, examines the thickness or thinness of the sample oil. The test measures the time for a volume of liquid to flow under gravity, determining the kinematic viscosity of oil at 40°C. Equipment manufacturers specify viscosity when indicating machine tolerance, bearing loads and the rate of heat removal.
- **100 degrees Celsius (additional test)** - The Viscosity 100° C test measures the thickness of the oil at a high operating temperature. Viscosity, or oil weight, examines the thickness or thinness of the sample oil. The test measures the time for a volume of liquid to flow under gravity, determining the kinematic viscosity of oil at 100°C.
- **Viscosity Index** - (VI) can be calculated from viscosity measurement at 40°C and 100°C using ASTM D2270. The VI can be trended and compared with new oil specifications to detect changes in the lubricant condition. With new, high speed used oil viscometers available, measuring the oil sample at both temperatures is very cost effective.

There are several additional tests e.g. TAN/TBN/VISC100 etc. that may be required for certain types of lube oils and our laboratory can carry out all of these on request.



FA-ST Filtration Analysis Services Technology Ltd  
Tel: +44 (0) 1246268900 E-Mail: [info@fa-st.co.uk](mailto:info@fa-st.co.uk)  
Web: [www.fa-st.co.uk](http://www.fa-st.co.uk) [www.howcleanisyouroil.com](http://www.howcleanisyouroil.com)

Co Reg Number: 05525184 Vat Reg Number: GB843 0628 38

